

ATTESTATION OF CONFORMITY

1085-0735

by the certification company „OFI CERT“ regarding the hygiene suitability for drinking water of

Product(s): **Sealing components made of KLINGERSIL® C-4240**
Material type: **KLINGERSIL® C-4240**
Risk Group: **P2 (including P3)**

Based on a type test (without external monitoring – simplified procedure)

of the manufacturer

Rich. Klinger Dichtungstechnik GmbH & Co. KG
Am Kanal 8-10, A-2352 Gumpoldskirchen, Austria

produced at the production site

Rich. Klinger Dichtungstechnik GmbH & Co. KG
Am Kanal 8-10, A-2352 Gumpoldskirchen, Austria

We hereby certify that the product / component indicated above

- **based on the certification programme ZI-21 (OFI CERT)**
- **the submitted product information, including the formulation details**
- **and the assessment documents (OFI 2101005-1)**

meets the requirements of the „Umweltbundesamt - Evaluation criteria for plastics and other organic materials in contact with drinking water (KTW-BWGL)“ (rev. 2022-03-07) for the product group ancillary components (P2) and application temperature 23°C and 85°C (cold water and hot water) and is in compliance with the above document.

The assessment documents¹⁾ are part of this attestation of conformity. This attestation of conformity was issued for the first time on 2023-08-30 and is valid from the date of issue below until 2028-08-29. Additionally the preconditions specified below under „Remarks“ have to be fulfilled.

Remarks:

The attestation of conformity is issued under the precondition that the starting materials used to manufacture the products and /or their composition and/or components, including their manufactures and supply chain, have been disclosed in full and the product does not contain any further substances. This document shall be invalid in case of changes to the composition of the product or the processing conditions that have not been agreed upon with the certification body, failure to meet the conformity requirements or termination of the 1+ system monitoring programme by OFI CERT and manufacturer.

The finding of our tests and the evaluations apply for the test objects examined and the provisions of the law applicable at the time of testing. Without our express written approval, it is only permitted to publish or reproduce this document in full and unedited.

Vienna, 30th of August 2023
(supersedes version from: new edition)


Mag. Sabrina Geiss, BSc.
Deputy Head of certification body OFI CERT

www.ofi.at

The certificate is listed at www.ofi.at/zertifizierung.

¹⁾ the assessment documents are kept on file in OFI CERT and are only used in justified cases (e.g. at the request of an authority).



Zertifizierungsstelle OFI CERT
OFI Technologie & Innovation GmbH
Arsenal, Franz-Grill-Straße 5
1030 Wien / Österreich

