

Approval Number 2112506  
Test Report: MA7373/T/1



13<sup>th</sup> October 2021

Rich. Klinger Dichtungstechnik GmbH & Co. KG  
Am Kanal 8-10  
A - 2352 Gumpoldskirchen  
Austria

Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)  
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**SEALANTS - FLAT FACED JOINTS- PTFE.**

**5480**

'Klinger® Top-Chem 2005'. Red coloured, filled PTFE gasket material manufactured by calendaring. For use with water up to 23°C.

**APPROVAL NUMBER: 2112506**

**APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO. KG**

This is a re-approval of 1611528 which is valid between November 2016 and November 2021.

The Scheme reserves the right to review approval.

Approval 2112506 is valid between December 2021 and December 2026

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

**Ian Hughes**  
**WRAS Approvals Manager**